



November 10, 2017

ADDENDUM NO. 2

To the Contract Documents for:

WAVE WATERPARK SPRAY GROUND REPLACEMENT PROJECT (C.I.P. NO. 8265/BUILDING PLAN NO. B17-0792)

City of Vista
200 Civic Center Drive
Vista, CA 92084-6240

A handwritten signature in black ink that reads "Therron Dieckmann". The signature is written in a cursive style and is positioned above a solid black horizontal line.

Therron Dieckmann
Director of Recreation and Community Services

To All Contract Document Holders of Record: All contract drawings, specifications, contract documents and other bidding directives remain unchanged except drawings, specifications, sections or parts of sections added to, revised, deleted or clarified by this Addendum.

CHANGES TO THE BIDDING AND CONTRACTURAL DOCUMENTS

QUESTIONS AND ANSWERS

1. *Are there specifications on the doors, frames? What type of hardware will be used for doors, frames? Is there a door schedule?*
 - a. *The equipment enclosure and doors are a part of a prefabricated enclosure per detail 4/WP-7. The recommended manufacturers are South Coast Controls (Attn: Anthony 714-998-5656), Nevwest (Attn: Leonard 619-420-8100), or equal.*

2. *What type of fencing are you looking for?*
 - a. *Existing fencing is to be repainted.*

END OF ADDENDUM NO. 2